

# **NEW JERSEY HIGH VOLTAGE PROXIMITY ACT REGULATIONS**

## **PROCEDURE IF CRANE IS WORKING IN CLOSE PROXIMITY WITH HIGH VOLTAGE LINES .**

- 1) power lines are considered high voltage if they exceed 750 volts
- 2) the crane must be at least working boom length plus 10 feet away from high voltage lines. If it is closer then the New Jersey public safety dept. and the local energy supplier must be contacted for permission and procedure for work. A site visit by these departments may be necessary.

## **CONTACTS**

### **NEW JERSEY PUBLIC SAFETY DEPARTMENT**

Steve Matthews- 609-292-2096 office, 908-334-4903 mobil

### **PSE&G**

Ed Iwanicki 973-318-9268 pager

### **GPU**

Service Dept. 1-800-662-3115

### **ORANGE-ROCKLAND ENERGY**

877-434-4100